



检 验 报 告

Test Report

NO:2023-JAJC-BG0288

委托单位: 广东胜捷消防技术有限公司

产品名称: 流量开关

产品型号: LLKG-XF DN100



玖安检测认证有限公司

Jiu'an testing and Certification Co.,Ltd

注 意 事 项

REMARKS

- 1、报告无本公司“检验报告专用章”无效，报告涂改无效。

The report is invalid without the company's "Inspection report special seal", and the report is invalid for alteration.

- 2、复制报告未重新加盖本公司“检验报告专用章”无效。

Copy the report is not re-stamped the company's "Inspection report special seal" is invalid.

- 3、报告无主检、审核、批准人签字无效。

The report is invalid without the signature of the principal inspector, Auditor and approver.

- 4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

- 5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

- 6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

- 7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.




玖安检测认证有限公司

检 验 报 告

NO:2023-JAJC-BG0288

第 1 页 共 3 页

产品名称	流量开关	商标	
型号规格	LLKG-XF DN100		
生 产 者	广东胜捷消防技术有限公司		
生产企业	广东胜捷消防技术有限公司		
检验类别	委托检验		
生产日期	2023 年 05 月	到样日期	2023 年 05 月 24 日
样品数量	1 台	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2023 年 05 月 25 日
检验依据	GB/T 13927-2008 《工业阀门 压力试验》		
检 验 项 目	壳体试验；密封试验		
检 验 结 论	经检验，所检项目符合 GB/T 13927-2008 标准要求，判定合格。  (检验检测专用章) 签发日期：2023 年 05 月 30 日		
备 注			

批准：林国辉

审核：陈瑞金

编制：黄小亮