



221302110727

检 验 报 告

Test Report

NO: 2023-JAJC-BG0373

委托单位: 科达阀门科技有限公司

产品名称: 微量排气阀

产品型号: ZFGPW1X(ARVX)-16Q DN20



玖安检测认证有限公司

Jiu'an testing and Certification Co.,Ltd

注 意 事 项

REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无主检、审核、批准人签字无效。

The report is invalid without the signature of the principal inspector, Auditor and approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

 玖安检测认证有限公司

检 验 报 告

NO:2023-JAJC-BG0373

第1页 共3页

产品名称	微量排气阀	商标	
型号规格	ZFGPW1X(ARVX)-16Q DN20		
生产者	科达阀门科技有限公司		
生产企业	科达阀门科技有限公司		
检验类别	委托检验		
生产日期	2023 年 05 月	到样日期	2023 年 06 月 10 日
样品数量	1 台	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2023 年 06 月 11 日
检验依据	GB/T 13927-2008 《工业阀门 压力试验》		
检 验 项 目	壳体试验；密封试验		
检 验 结 论	经检验，所检项目符合 GB/T 13927-2008 标准要求，判定合格。  签发日期：2023 年 06 月 16 日		
备 注			

批准：陈华荣

审核：陈瑞金

编制：黄小亮