



221302110727

# 检验报告

## Test Report

NO:2023-JAJC-BG0059

委托单位：福建越海阀门有限公司

产品名称：泡沫消火栓箱

产品型号：PSG30、PSG45



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

# 注意事項

## REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report , please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

---

地址：福建省泉州市南安市溪美街道安山路1号      电话：0595-86068119

网址：[www.jajczx.com](http://www.jajczx.com)    邮箱：[jiuantesting@163.com](mailto:jiuantesting@163.com)    邮编：362300





## 检验报告

NO:2023-JAJC-BG0059

第1页 共5页

产品名称	泡沫消火栓箱	商标	
型号规格	PSG30、PSG45		
生产者	福建越海阀门有限公司		
生产企业	福建越海阀门有限公司		
检验类别	型式试验		
生产日期	2023年	到样日期	2023年06月17日
样品数量	主型2套，分型1套	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2023年06月18日
检验依据	GB 20031-2005《泡沫灭火系统及部件通用技术条件》		
检验项目	构成；标志；箱体；消防卷盘；泡沫比例混合器；泡沫液储罐；主要性能参数		
检验结论	经检验，所检项目符合 GB 20031-2005 标准要求，判定合格。		
备注	PSG30 为主型。		

批准: 陈瑞金

审核: 陈华荣

编制: 黄小亮

