



221302110727

检验报告

Test Report

NO:2024-JAJC-BG0624



委托单位：福建省中舜消防阀门有限公司

产品名称：自动跟踪定位射流灭火装置

型号规格：ZDMS0.6/10S-ZSXF、

ZDMS0.6/5S-ZSXF



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

注意事項

REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report , please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.





检验报告

NO:2024-JAJC-BG0624

第1页 共7页

产品名称	自动跟踪定位射流灭火装置	商标	中舜
型号规格	ZDMS0.6/10S-ZSXF、ZDMS0.6/5S-ZSXF		
生产者	福建省中舜消防阀门有限公司		
生产企业	福建省中舜消防阀门有限公司		
检验类别	型式试验		
生产日期	2024年	到样日期	2024年04月03日
样品数量	主型3套，分型2套	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2024年04月05日
检验依据	GB 25204-2010《自动跟踪定位射流灭火系统》		
检验项目	外观、结构、水平回转角和俯仰回转角；性能参数；高低温性能；耐湿热性能；绝缘电阻；介电强度；抗环境光线干扰性能；电压波动适应能力；灭火性能；自动控制的要求；系统的消防供液的要求；系统的后备电源供配要求；系统的现场档案视频记录要求；系统运行的可靠性能		
检验结论	经检验，所检项目符合 GB 25204-2010 标准要求，判定合格。		
备注	ZDMS0.6/10S-ZSXF 为主型。		

批准: 陈瑞金

审核: 陈华荣

编制: 黄小亮

