



221302110727



中国认可  
国际互认  
检测  
TESTING  
CNAS L20939

# 检验报告

## Test Report

NO:2024-JAJC-BG2400

委托单位：泉州市山河消防技术有限公司

产品名称：低倍数空气泡沫产生器

型号规格：PCL24、PCL4、PCL8、PCL16

检验类别：型式试验



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

# 注意事項

## REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.





## 检验报告

NO:2024-JAJC-BG2400

第1页 共8页

产品名称	低倍数空气泡沫产生器	商标	
型号规格	PCL24、PCL4、PCL8、PCL16		
生产者	泉州市山河消防技术有限公司		
生产企业	泉州市山河消防技术有限公司		
检验类别	型式试验		
生产日期	2024年	到样日期	2024年11月22日
样品数量	主型2套，分型各1套	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2024年11月23日
检验依据	GB 20031-2005《泡沫灭火系统及部件通用技术条件》		
检验项目	标志；外观；材料；连接型式和尺寸；主要性能参数；耐水冲击要求；导流板性能；密封玻璃性能		
检验结论	经检验，所检项目符合 GB 20031-2005 标准要求，判定合格。		
备注	PCL24 为主型。		

批准: 陈瑞金

审核: 戴少阳

编制: 廖其轩

